



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3H2437

Freeport Area School District

Project Name: Lead samples

Eric Mailki
PO BOX C
Freeport, PA 16229

Project / PO Number: N/A
Received: 08/11/2023
Reported: 08/16/2023

Analytical Testing Parameters

Client Sample ID:	HS-WC-019 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 8:30
Lab Sample ID:	A3H2437-01		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.438	0.400	ug/L	1		08/15/23 1547	08/15/23 1547	SEA

Client Sample ID:	HS-WC-019 Purge	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 8:32
Lab Sample ID:	A3H2437-02		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1557	08/15/23 1557	SEA

Client Sample ID:	HS-KS-020 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 8:50
Lab Sample ID:	A3H2437-03		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.728	0.400	ug/L	1		08/15/23 1559	08/15/23 1559	SEA

Client Sample ID:	HS-KS-020 Purge	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 8:52
Lab Sample ID:	A3H2437-04		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1602	08/15/23 1602	SEA

Client Sample ID:	HS-KS-021 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:05
Lab Sample ID:	A3H2437-05		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1			08/15/23 1605	SEA



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3H2437

Client Sample ID:	HS-KS-021 Purge	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:06
Lab Sample ID:	A3H2437-06		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1607	08/15/23 1607	SEA

Client Sample ID:	HS-KS-023 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:09
Lab Sample ID:	A3H2437-07		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	9.88	0.400	ug/L	1		08/15/23 1610	08/15/23 1610	SEA

Client Sample ID:	HS-KS-023 Purge	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:10
Lab Sample ID:	A3H2437-08		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	3.93	0.400	ug/L	1		08/15/23 1612	08/15/23 1612	SEA

Client Sample ID:	HS-KS-022 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:15
Lab Sample ID:	A3H2437-09		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.777	0.400	ug/L	1		08/15/23 1615	08/15/23 1615	SEA

Client Sample ID:	HS-KS-022 Purge	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:17
Lab Sample ID:	A3H2437-10		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1617	08/15/23 1617	SEA

Client Sample ID:	HS-WC-027 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:28
Lab Sample ID:	A3H2437-11		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.666	0.400	ug/L	1		08/15/23 1627	08/15/23 1627	SEA



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3H2437

Client Sample ID:	HS-WC-027 Purge	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:30
Lab Sample ID:	A3H2437-12		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.567	0.400	ug/L	1		08/15/23 1638	08/15/23 1638	SEA

Client Sample ID:	HS-TL-004 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:38
Lab Sample ID:	A3H2437-13		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	2.66	0.400	ug/L	1		08/15/23 1640	08/15/23 1640	SEA

Client Sample ID:	HS-TL-004 Purge	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:40
Lab Sample ID:	A3H2437-14		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	1.26	0.400	ug/L	1		08/15/23 1643	08/15/23 1643	SEA

Client Sample ID:	HS-TL-005 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:48
Lab Sample ID:	A3H2437-15		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1645	08/15/23 1645	SEA

Client Sample ID:	HS-TL-005 Purge	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:50
Lab Sample ID:	A3H2437-16		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1648	08/15/23 1648	SEA

Client Sample ID:	HS-CF-006 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 9:55
Lab Sample ID:	A3H2437-17		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.587	0.400	ug/L	1		08/15/23 1650	08/15/23 1650	SEA



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3H2437

Client Sample ID:	HS-EC-009 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 10:00
Lab Sample ID:	A3H2437-18		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.689	0.400	ug/L	1		08/15/23 1653	08/15/23 1653	SEA

Client Sample ID:	HS-EC-011 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 10:05
Lab Sample ID:	A3H2437-19		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	1.27	0.400	ug/L	1			08/15/23 1656	SEA

Client Sample ID:	HS-EC-012 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 10:07
Lab Sample ID:	A3H2437-20		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	1.09	0.400	ug/L	1		08/15/23 1658	08/15/23 1658	SEA

Client Sample ID:	HS-EC-013 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 10:10
Lab Sample ID:	A3H2437-21		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	1.21	0.400	ug/L	1		08/15/23 1716	08/15/23 1716	SEA

Client Sample ID:	Administration Sink Admin-KS-001A First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 10:20
Lab Sample ID:	A3H2437-22		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1724	08/15/23 1724	SEA

Client Sample ID:	BES Kitchen Sink 1 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 10:32
Lab Sample ID:	A3H2437-23		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1726	08/15/23 1726	SEA



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3H2437

Client Sample ID: BES Kitchen Sink 3 Kettle First	Collected By: Tim McLaughlin
Sample Matrix: Drinking Water	Collection Date: 08/11/2023 10:35
Lab Sample ID: A3H2437-24	

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1729	08/15/23 1729	SEA

Client Sample ID: BES ___ 2 Sink First	Collected By: Tim McLaughlin
Sample Matrix: Drinking Water	Collection Date: 08/11/2023 10:40
Lab Sample ID: A3H2437-25	

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1731	08/15/23 1731	SEA

Client Sample ID: BES ___ 3 Sink First	Collected By: Tim McLaughlin
Sample Matrix: Drinking Water	Collection Date: 08/11/2023 10:45
Lab Sample ID: A3H2437-26	

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1734	08/15/23 1734	SEA

Client Sample ID: SB-KS-005 First	Collected By: Tim McLaughlin
Sample Matrix: Drinking Water	Collection Date: 08/11/2023 11:18
Lab Sample ID: A3H2437-27	

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1736	08/15/23 1736	SEA

Client Sample ID: SB-KS-006 First	Collected By: Tim McLaughlin
Sample Matrix: Drinking Water	Collection Date: 08/11/2023 11:22
Lab Sample ID: A3H2437-28	

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1739	08/15/23 1739	SEA

Client Sample ID: SB-KS-007 First	Collected By: Tim McLaughlin
Sample Matrix: Drinking Water	Collection Date: 08/11/2023 11:25
Lab Sample ID: A3H2437-29	

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1741	08/15/23 1741	SEA



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3H2437

Client Sample ID:	SB-WC-018 First	Collected By:	Tim McLaughlin
Sample Matrix:	Drinking Water	Collection Date:	08/11/2023 11:30
Lab Sample ID:	A3H2437-30		

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	0.400	ug/L	1		08/15/23 1744	08/15/23 1744	SEA

Definitions

RL: Reporting Limit
 ug/L: Micrograms per Liter

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division
 02-00257

Pennsylvania Department of Environmental Protection
 Pennsylvania Department of Environmental Protection - PARULE

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.***

Reviewed and Approved By:



Rachel McCoy
 Client Relations Specialist
 Reported: 08/16/2023 14:58



Chain of Custody

Microbac Laboratories Inc., Pittsburgh Division

Lab Contact: Carolyn Vollentine



A3H2437

TAT 7 days

Page 7 of 15

Freeport Area School District

Project Name: Lead samples

Eric Mailki
PO BOX C
Freeport, PA 16229
Phone: (724) 295-5143
mailki@freeport.k12.pa.us

Project/PO Number: N/A
Tenatively Scheduled: 8/10/2023
Route:

HNO₃ Preserved
HNO₃: A304288
Date: 8/10/23
Time: 13:59
Initials: JAC

Client Sample ID: Sample HS-WC-019, FIRST DRAW

Lab Sample ID: A3H2437-01

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 8:30

Type:

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
Admin ENV Consulting	NA		9,999 days
		Container(s) 250ml-Bottle HDPE	Designator A

Client Sample ID: Sample HS-WC-019, PURGE SAMPLE

Lab Sample ID: A3H2437-02

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 8:32

Type:

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		Container(s) 250ml-Bottle HDPE	Designator A

Client Sample ID: Sample HS-KS-020, FIRST DRAW

Lab Sample ID: A3H2437-03

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 8:50

Type:

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		Container(s) 250ml-Bottle HDPE	Designator A

Client Sample ID: Sample HS-KS-020, PURGE SAMPLE

Lab Sample ID: A3H2437-04

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 8:52

Type:



Freeport Area School District

Project Name: Lead samples

Eric Mailki
 PO BOX C
 Freeport, PA 16229
 Phone: (724) 295-5143
 mailki@freeport.k12.pa.us

Project/PO Number: N/A
 Tentatively Scheduled: 8/10/2023
 Route:

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		Container(s) 250ml-Bottle HDPE	Designator A

Client Sample ID: Sample *HS-KS-021, First Draw*
 Lab Sample ID: A3H2437-05
 Matrix: Drinking Water
 Type:
 Sampled Date & Time: 8-11-23 9:05

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		Container(s) 250ml-Bottle HDPE	Designator A

Client Sample ID: Sample *HS-KS-021, Purge Sample*
 Lab Sample ID: A3H2437-06
 Matrix: Drinking Water
 Type:
 Sampled Date & Time: 8-11-23 9:06

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		Container(s) 250ml-Bottle HDPE	Designator A

Client Sample ID: Sample *HS-KS-023, First Draw*
 Lab Sample ID: A3H2437-07
 Matrix: Drinking Water
 Type:
 Sampled Date & Time: 8-11-23 9:09

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		Container(s) 250ml-Bottle HDPE	Designator A



Freeport Area School District

Project Name: Lead samples

Eric Mailki
 PO BOX C
 Freeport, PA 16229
 Phone: (724) 295-5143
 mailki@freeport.k12.pa.us

Project/PO Number: N/A
 Tentatively Scheduled: 8/10/2023
 Route:

Client Sample ID: Sample

*HS-KS-022⁰²³, Purge Samples
 The
 8-11-23*

Lab Sample ID: A3H2437-08

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 9:10

Type:

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		Container(s) 250ml-Bottle HDPE	Designator A

Client Sample ID: Sample

HS-KS-022, FIRST DRAW

Lab Sample ID: A3H2437-09

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 9:15

Type:

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		Container(s) 250ml-Bottle HDPE	Designator A

Client Sample ID: Sample

HS-KS-022, Purge Samples

Lab Sample ID: A3H2437-10

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 9:17

Type:

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		Container(s) 250ml-Bottle HDPE	Designator A

Client Sample ID: Sample

HS-WC-027, FIRST DRAW

Lab Sample ID: A3H2437-11

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 9:28

Type:

Analysis	Method	Field Results/Comments	Hold Time



Freeport Area School District

Project Name: Lead samples

Eric Mailki
 PO BOX C
 Freeport, PA 16229
 Phone: (724) 295-5143
 mailki@freeport.k12.pa.us

Project/PO Number: N/A
 Tentatively Scheduled: 8/10/2023
 Route:

200.8 Pb	EPA 200.8, Rv. 5.4 (1994)	180 days
	<u>Container(s)</u> 250ml-Bottle HDPE	<u>Designator</u> A

Client Sample ID: Sample *HS-WC-027, PURES SAMPLE*
 Lab Sample ID: A3H2437-12
 Matrix: Drinking Water
 Type: Sampled Date & Time: 8-11-23 9:30

<u>Analysis</u>	<u>Method</u>	<u>Field Results/Comments</u>	<u>Hold Time</u>
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
	<u>Container(s)</u> 250ml-Bottle HDPE		<u>Designator</u> A

Client Sample ID: Sample *HS-TL-004, FIRST DRAW*
 Lab Sample ID: A3H2437-13
 Matrix: Drinking Water
 Type: Sampled Date & Time: 8-11-23 9:38

<u>Analysis</u>	<u>Method</u>	<u>Field Results/Comments</u>	<u>Hold Time</u>
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
	<u>Container(s)</u> 250ml-Bottle HDPE		<u>Designator</u> A

Client Sample ID: Sample *HS-TL-004, PURES SAMPLE*
 Lab Sample ID: A3H2437-14
 Matrix: Drinking Water
 Type: Sampled Date & Time: 8-11-23 9:40

<u>Analysis</u>	<u>Method</u>	<u>Field Results/Comments</u>	<u>Hold Time</u>
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
	<u>Container(s)</u> 250ml-Bottle HDPE		<u>Designator</u> A


Freeport Area School District
Project Name: Lead samples

 Eric Mailki
 PO BOX C
 Freeport, PA 16229
 Phone: (724) 295-5143
 mailki@freeport.k12.pa.us

 Project/PO Number: N/A
 Tentatively Scheduled: 8/10/2023
 Route:

Client Sample ID: Sample *HS-TL-005, FIRST DRAW*
Lab Sample ID: A3H2437-15

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 9:48
Type:

<u>Analysis</u>	<u>Method</u>	<u>Field Results/Comments</u>	<u>Hold Time</u>
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		<u>Container(s)</u> 250ml-Bottle HDPE	<u>Designator</u> A

Client Sample ID: Sample *HS-TL-005, PURGE SAMPLE*
Lab Sample ID: A3H2437-16

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 9:50
Type:

<u>Analysis</u>	<u>Method</u>	<u>Field Results/Comments</u>	<u>Hold Time</u>
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		<u>Container(s)</u> 250ml-Bottle HDPE	<u>Designator</u> A

Client Sample ID: Sample *HS-CF-006, FIRST DRAW*
Lab Sample ID: A3H2437-17

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 9:55
Type:

<u>Analysis</u>	<u>Method</u>	<u>Field Results/Comments</u>	<u>Hold Time</u>
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		<u>Container(s)</u> 250ml-Bottle HDPE	<u>Designator</u> A

Client Sample ID: Sample *HS-CF-006, PURGE SAMPLE HS-EC-009, FIRST DRAW*
Lab Sample ID: A3H2437-18

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 10:00
Type:

<u>Analysis</u>	<u>Method</u>	<u>Field Results/Comments</u>	<u>Hold Time</u>



Chain of Custody

Microbac Laboratories Inc., Pittsburgh Division

Lab Contact: Carolyn Vollentine



A3H2437

Page 12 of 15

Freeport Area School District

Project Name: Lead samples

Eric Mailki
PO BOX C
Freeport, PA 16229
Phone: (724) 295-5143
mailki@freeport.k12.pa.us

Project/PO Number: N/A
Tenatively Scheduled: 8/10/2023
Route:

200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		<u>Container(s)</u> 250ml-Bottle HDPE	<u>Designator</u> A

Client Sample ID: Sample *HS-EC-011, FIRST DRAW*

Lab Sample ID: A3H2437-19

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 10:05

Type:

<u>Analysis</u>	<u>Method</u>	<u>Field Results/Comments</u>	<u>Hold Time</u>
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		<u>Container(s)</u> 250ml-Bottle HDPE	<u>Designator</u> A

Client Sample ID: Sample *HS-EC-012, FIRST DRAW*

Lab Sample ID: A3H2437-20

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 10:07

Type:

<u>Analysis</u>	<u>Method</u>	<u>Field Results/Comments</u>	<u>Hold Time</u>
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		<u>Container(s)</u> 250ml-Bottle HDPE	<u>Designator</u> A

Client Sample ID: Sample *HS-EC-013, FIRST DRAW*

Lab Sample ID: A3H2437-21

Matrix: Drinking Water

Sampled Date & Time: 8-11-23 10:10

Type:

<u>Analysis</u>	<u>Method</u>	<u>Field Results/Comments</u>	<u>Hold Time</u>
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		<u>Container(s)</u> 250ml-Bottle HDPE	<u>Designator</u> A



Freeport Area School District

Project Name: Lead samples

Eric Maiki
 PO BOX C
 Freeport, PA 16229
 Phone: (724) 295-5143
 maiki@freeport.k12.pa.us

Project/PO Number: N/A
 Tentatively Scheduled: 8/10/2023
 Route:

Client Sample ID: Sample *ADMINISTRATION, SINK ADMIN-KS-001A, FIRST DRAW*
 Lab Sample ID: A3H2437-22
 Matrix: Drinking Water
 Type:
 Sampled Date & Time: 8-11-23 10:20

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		Container(s) 250ml-Bottle HDPE	Designator A

Client Sample ID: Sample *BES, KITCHEN SINK 1, FIRST DRAW*
 Lab Sample ID: A3H2437-23
 Matrix: Drinking Water
 Type:
 Sampled Date & Time: 8-11-23 10:32

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		Container(s) 250ml-Bottle HDPE	Designator A

Client Sample ID: Sample *BES, KITCHEN SINK 3 (KETTLE), FIRST DRAW*
 Lab Sample ID: A3H2437-24
 Matrix: Drinking Water
 Type:
 Sampled Date & Time: 8-11-23 10:35

Analysis	Method	Field Results/Comments	Hold Time
200.8 Pb	EPA 200.8, Rv. 5.4 (1994)		180 days
		Container(s) 250ml-Bottle HDPE	Designator A

Client Sample ID: Sample *BES, RESSURGE 2 SINK, FIRST DRAW*
 Lab Sample ID: A3H2437-25
 Matrix: Drinking Water
 Type:
 Sampled Date & Time: 8-11-23 10:40

Analysis	Method	Field Results/Comments	Hold Time

- 28) SB-KS-006, FIRST DRAW 8-11-23 11:22
- 29) SB-KS-007, FIRST DRAW 8-11-23 11:25
- 30) ~~SB-KS-~~TH 8-11-23
SB-WC-018, FIRST DRAW 8-11-23 11:30



A 3 H 2 4 3 7
Freeport Area School District
PM: Carolyn Volentine